

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1501:124

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Edwards Signaling, 8985 Towne Center Parkway, Badenton, FL 34202
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

DESIGN: Models 107, followed by D or DD; followed by V2P; followed by ST or RINH; followed by A, B, C, G, M or R; followed by N5, R5, EK, S1 or G1 Adaptabeacon strobe and beacon lights. For use in hazardous locations, Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class II, Division 2, Groups F and G; Class III, Divisions 1 and 2. For indoor or outdoor use, Type 3R and 4.

Models 107 followed by D or DD; followed by V2B or V2C; followed by ST or RINH; followed by A, B, C, G, M or R; followed by N5, R5, EK, S1 or G1. For use in hazardous locations, Class I, Divisions 2, Groups A, B, C and D. For indoor or outdoor use, Type 3R and 4.

The devices employ the use of a pendant, ceiling or wall bracket connected to an enclosure with the pendant being of dust-ignition-proof construction. The devices also employ a circuit board containing electrical components with a gas discharge flash tube or an incandescent lamp surrounded by a rotating reflector. Depending on the model, the flash tube or the rotating reflector are enclosed in a clear blue, red, green, or amber globe.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 120 VAC, 24 VDC, 240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as hazardous location strobe lights. Not to be used as a visual public mode alarm notification appliance and not suitable for hearing impaired application.

*Rev. 05-24-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division